



13415 East Route 17, Grant Park, IL; 60940
(815) 465-2102 - Phone / (815) 465-2104 – Fax

Typical Specification Paragraph

We are pleased you are considering our GAL-7, GAL-5 and our other products for use in potential engineered sprinkler jobs. The following is a Specification “blurb” others have included in one form another into their engineering specifications.

Dry System Piping Requirements:

Pipe:

All dry sprinkler pipe systems must meet Factory Mutual (FM) requirements for Galvanized pipe (ASTM 53 zinc coating, FM Approved Galvanizing facility). Galvanized Schedule 10 or 40 FM Approved. Galvanized pipe less than schedule 10 **must pass ASTM A653 zinc adhesion test – as approved by FM.** (IDOD GAL-5, GAL-7 Acceptable Manufacturer). All piping must be used in conjunction with limitations of listing or approval agencies.